



EU & RoHS Declaration of Conformity

We,  
**General Industrial Controls Private Limited**, T-107, MIDC, Bhosari, Pune 411 026 (Maharashtra State) India +91-20-46232323, [Info@gicindia.com](mailto:Info@gicindia.com), [www.gicindia.com](http://www.gicindia.com); declare under sole responsibility that the following described products in our delivered version comply with the appropriate basic safety and health requirements of the:

1. Low Voltage Directive – 2014/35/EU	2. EMC Directive – 2014/30/EU	3. RoHS Directive 2011/65/EU
---------------------------------------	-------------------------------	------------------------------

Based on its design and type, as brought into circulation by us.

*(In case of alteration of the product by the user, not agreed upon by us, this declaration will lose its validity.)*

**Description of the Product:**

Series /Nomenclatures: **CMR Series**

Sr. No.	Catalog Numbers	Description	Product Revision
1	ELR3A2030	INTEGRAL EARTH LEAKAGE RELAY,35mm CBCT, 240VAC(±15% ), 50/60Hz, 30 mA	R000
2	ELR3A2100	INTEGRAL EARTH LEAKAGE RELAY,35mm CBCT, 240VAC(±15% ), 50/60Hz, 100 mA	R000
3	ELR3A2300	INTEGRAL EARTH LEAKAGE RELAY,35mm CBCT, 240VAC(±15% ), 50/60Hz, 300 mA	R000

**Applicable Harmonized Standards: Under EMC & LVD Directives:**

Ref. No.	Title
IEC 61000-4-2	Electrostatic Discharge (ESD) Immunity Test
IEC 61000-4-3	Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	Electrical Fast Transient / Burst immunity test
IEC 61000-4-5	Surge Immunity test
IEC 61000-4-6	Conducted Susceptibility (Immunity to conducted disturbances, induced by radio-frequency fields)
IEC 61000-4-8	Power frequency magnetic field immunity test
IEC 61000-4-11	Voltage dips, short interruptions & Voltage variations immunity tests for AC input ports
IEC 61010-1	Di-electric Strength (Safety requirements for electrical equipment for measurement, control, and Laboratory use)
CISPR-11	Conducted & Radiated Emissions

**RoHS Directive 2011/65/EC** of the European Parliament & of the council regarding the limitation of dangerous substances.

Year in which CE Marking was affixed: 2021

Name of Company: General Industrial Controls Pvt. Ltd.

Date: 12-FEB-2021.

Name of Signatory: Rajan Rane Title / Designation: Manager (Product Engg)	Name of Signatory: Vijay Waykole Title / Designation: General Manager (Material Management)	Name of Signatory: Shrihari kshirsagar. Title / Designation: Manager (Quality)
CE		

Document Ref. No: EC05321